

Modification Document – Proposed On-Site Fuel Storage

Northland Power Glendale G.P.

July 16, 2018

Table of Contents

1.0	Introduction	.3	
2.0	Proposed Project Change	.4	
2.1	Change	.4	
2.2	Rational for Change	.4	
2.3	Addition Environmental Risks and Mitigation	.4	
3.0	Summary of Revisions to REA Supporting Documents	.4	
3.1	Construction Report	.4	
3.2	Design and Operation Report	.5	
3.4	Decommissioning Report	.5	
3.5	Heritage Assessment Report		
3.6	Project Description Report		
3.7	Protected Properties Assessment		
3.8	Water Assessment Report		
3.9	Natural Heritage Assessment and Environmental Impact Study5		
3.10	Noise Assessment Study Report6		

List of Appendices

Appendix A – Site Plan

1.0 Introduction

The Glendale Solar Project ("the Project") was developed in 2012 by Northland Power Inc. on behalf of Northland Power Solar Glendale G.P. ("Northland") under Renewable Energy Approval Number 1565-8ULQT7 on June 26, 2012.

Since beginning commercial operation, a need for on-site fuel storage has been identified that was not contemplated during the development of the project. Heavy snow accumulation on the solar panels during the winter months has had significant negative impact on the facility's production levels and as a result Northland will utilize mechanical snow removal technology at the Project site to mitigate further impacts to performance. In order to operate the proposed snow removal equipment a small volume of diesel fuel is required to be stored on-site so Northland plans to install a fuel tank prior to the winter of 2018-2019.

The tank is to be installed and operated so that it is in compliance with the MOECC's Guidelines for Environmental Protection Measures at Chemical and Waste Storage Facilities as well applicable Technical Standards and Safety Association (TSSA) regulations. A site plan depicting the proposed installation of the tank can be found in appendix A.

This report summarizes the proposed changes to the project that necessitate an amendment of the REA. This includes the rational for the change and will identify amendments to be made to the REA's supporting documents if necessary.

2.0 Proposed Project Change

Appendix A contains a site plan drawing indicating the installation location of the proposed fuel tank.

2.1 Change

Installation of a small fuel storage tank at the Project site.

2.2 Rational for Change

Storage of diesel is required on-site to fuel maintenance equipment. The need for on-site storage of fuel was not contemplated during the development of the Project.

2.3 Addition Environmental Risks and Mitigation

The risk of releasing diesel fuel to the natural environment is mitigated by the double-walled design of the proposed fuel tank which is design to the latest version of CAN/ULC-601. The tank will be installed and operated in accordance with the MOECC's Guidelines for Environmental Protection Measures at Chemical and Waste Storage Facilities as well as the applicable TSSA regulations for liquid fuel storage.

3.0 Summary of Revisions to REA Supporting Documents

This section addresses amendments to the supporting documents submitted with the REA application necessitated by the changes proposed in this document.

3.1 Construction Report

No material changes. Existing project infrastructure will be utilized to access fuel tank location.

3.2 Design and Operation Report

Page	Section	Original Text	Amended Text
8	3.2.6	Not Applicable	On-Site Fuel Storage
			A fuel storage tank may be
			installed at the Project site to
			facilitate the operation of
			maintenance related equipment.
			The fuel storage tank will be
			installed in accordance with
			Ministry of Environment and
			Climate Change's Guidelines for
			Environmental Protection
			Measures at Chemical and Waste
			Storage Facilities as well as
			applicable TSSA regulations and
			any other applicable legislation,
			regulations, standards, codes, or
			practices.

3.4 Decommissioning Report

No material changes.

3.5 Heritage Assessment Report

No material changes.

3.6 Project Description Report

No material changes.

3.7 Protected Properties Assessment

No material changes.

3.8 Water Assessment Report

No material changes.

3.9 Natural Heritage Assessment and Environmental Impact Study

No material changes.

3.10 Noise Assessment Study Report

No material changes. No noise emitting equipment will be installed or moved as a result of the changes proposed in the document.

Appendix A

Site Plan

