

---

**AMENDMENT TO RENEWABLE ENERGY APPROVAL**NUMBER 5636-8RAM88  
Issue Date: June 19, 2014

Northland Power Solar McCann GP Inc.  
30 St.Clair Avenue West, 17 th Floor  
Toronto, Ontario  
M4V 3A1

Site Location: 878 McCann Road  
Lot 1, Conc. 1  
Rideau Lakes Township, United Counties of Leeds and Grenville  
K0G 1V0

*You are hereby notified that I have amended Approval No. 5636-8RAM88 issued on February 29, 2012 for a Class 3 solar project , as follows:*

- A. The definitions of "Acoustic Assessment Report" and "Application" in the Approval are deleted and replaced by the following:**
1. "Acoustic Assessment Report" means the report included in the Application and entitled "Noise Assessment Study Report, McCann Solar Project", prepared by HATCH, dated April 11, 2014, and signed by Aaron Peng and Mervyn Choy;
  4. "Application" means the application for a Renewable Energy Approval dated June 28, 2011, and signed by John Brace, President and CEO, Northland Power Solar McCann GP Inc., on behalf of Northland Power Solar McCann LP, and all supporting documentation submitted with the application, including amended documentation submitted up to January 19, 2012, and as further amended by the application for a Renewable Energy Approval dated December 13, 2013 and signed by Jim Mulvale, Manager EH&S, Northland Power Inc., and all supporting documentation submitted with the application, including amended documentation submitted up to June 2, 2014.

**B. The Schedule A in the Approval is deleted and replaced by the following:**

**SCHEDULE A**

**Coordinates of the Equipment and Noise Specifications**

Coordinates of the Equipment are listed below in UTM, Z17-NAD83 projection:

| Source ID | Sound Power Level (dBA) | Easting (m) | Northing (m) | Source Description       |
|-----------|-------------------------|-------------|--------------|--------------------------|
| Mc_Inv1   | 91.3                    | 398804.6    | 4948422.6    | Inverters at Cluster 1   |
| Mc_Inv2   | 91.3                    | 398917.7    | 4948529      | Inverters at Cluster 2   |
| Mc_Inv3   | 91.3                    | 398957.8    | 4948666.5    | Inverters at Cluster 3   |
| Mc_Inv4   | 91.3                    | 398993.8    | 4948814.8    | Inverters at Cluster 4   |
| Mc_Inv5   | 91.3                    | 399183.3    | 4948919.8    | Inverters at Cluster 5   |
| Mc_Inv6   | 91.3                    | 399186.8    | 4948714.2    | Inverters at Cluster 6   |
| Mc_Inv7   | 91.3                    | 399289.1    | 4948606.3    | Inverters at Cluster 7   |
| Mc_Trans1 | 80.1                    | 398809.9    | 4948422.2    | Transformer at Cluster 1 |
| Mc_Trans2 | 80.1                    | 398923      | 4948528.5    | Transformer at Cluster 2 |
| Mc_Trans3 | 80.1                    | 398963.1    | 4948666.1    | Transformer at Cluster 3 |
| Mc_Trans4 | 80.1                    | 398999.1    | 4948814.4    | Transformer at Cluster 4 |
| Mc_Trans5 | 80.1                    | 399188.7    | 4948919.3    | Transformer at Cluster 5 |
| Mc_Trans6 | 80.1                    | 399192.1    | 4948713.7    | Transformer at Cluster 6 |
| Mc_Trans7 | 80.1                    | 399294.4    | 4948605.8    | Transformer at Cluster 7 |
| Mc_Sub    | 90.8                    | 399148.5    | 4948483.6    | Transformer Substation   |

Note: The inverter and transformer Sound Power Level values in the above table correspond to the combined output of all the inverters in each cluster, and include the 5 Decibel (dB) adjustment for tonality as prescribed in Publication NPC-104.

**All other Terms and Conditions of the Approval remain the same.**

**This Notice shall constitute part of the approval issued under Approval No. 5636-8RAM88 dated**

*In accordance with Section 139 of the Environmental Protection Act, within 15 days after the service of this notice, you may by further written notice served upon the Director, the Environmental Review Tribunal and the Environmental Commissioner, require a hearing by the Tribunal.*

*In accordance with Section 47 of the Environmental Bill of Rights, 1993, the Environmental Commissioner will place notice of your request for a hearing on the Environmental Registry.*

*Section 142 of the Environmental Protection Act provides that the notice requiring the hearing shall state:*

1. The portions of the renewable energy approval or each term or condition in the renewable energy approval in respect of which the hearing is required, and;

2. The grounds on which you intend to rely at the hearing in relation to each portion appealed.

*The signed and dated notice requiring the hearing should also include:*

3. The name of the appellant;
4. The address of the appellant;
5. The renewable energy approval number;
6. The date of the renewable energy approval;
7. The name of the Director;
8. The municipality or municipalities within which the project is to be engaged in;

*This notice must be served upon:*

The Secretary\*  
Environmental Review Tribunal  
655 Bay Street, 15th Floor  
Toronto, Ontario  
M5G 1E5

AND

The Environmental Commissioner  
1075 Bay Street, 6th Floor  
Suite 605  
Toronto, Ontario  
M5S 2B1

AND

The Director  
Section 47.5, *Environmental Protection Act*  
Ministry of the Environment  
2 St. Clair Avenue West, Floor 12A  
Toronto, Ontario  
M4V 1L5

**\* Further information on the Environmental Review Tribunal's requirements for an appeal can be obtained directly from the Tribunal at: Tel: (416) 314-4600, Fax: (416) 314-4506 or [www.ert.gov.on.ca](http://www.ert.gov.on.ca)**

*Under Section 142.1 of the Environmental Protection Act, residents of Ontario may require a hearing by the Environmental Review Tribunal within 15 days after the day on which notice of this decision is published in the Environmental Registry. By accessing the Environmental Registry at [www.ebr.gov.on.ca](http://www.ebr.gov.on.ca), you can determine when this period ends.*

*Approval for the above noted renewable energy project is issued to you under Section 47.5 of the Environmental Protection Act subject to the terms and conditions outlined above.*

DATED AT TORONTO this 19th day of June, 2014



---

Ian Parrott, P.Eng.  
Director  
Section 47.5, *Environmental Protection Act*

YB/

c: District Manager, MOE Kingston - District  
Sean Male, Hatch

