
# DESIGN SPECIFICATIONS AND OPERATION DATA: SINGLE LINE DIAGRAM OF PROPOSED ELECTRICAL CONNECTION



## NOTES:

- 1. Rating of 115 and 34 kV equipment as required by applicable standards and rules.
- 2. 34 kV outdoor or indoor type switchgear.
- 3. Farm electrical protection as per industry requirements.
- 4. It is proposed that 115 kV line from windfarm to HONI S2B line will arrive at 90° and the connection point will be at S2B line tower. The tower will be selected later.

## **IMPEDANCE TABLES:**

#### 1. TAP LINE

	Underwater Cable	Overhead Transmission Line	
Voltage	115 kV	115 kV	
Length	1.5 km		
Impedance (pu on 118.05 kV, 100 MVA)	0.09015+j0.345 ohms 0.00065+j0.00248 pu	0.576+j4.9135 ohms 0.00413+j0.03526 pu	
Charging (pu on 118.05 kV, 100 MVA)	9.615x10 <sup>-5</sup> mhos 0.01340 pu	3.364x10 <sup>-5</sup> mhos 0.00469 pu	

#### 2. COLLECTOR SYSTEM

Feeder #	Equivalent Impedance (Ohm)	Equivalent Impedance (pu)	Charging (Mhos, pu)
1	0.569+j1.369	0.04781+j0.11502	7.49x10 <sup>-5</sup> , 0.00089
2	0.569+j1.369	0.04781+j0.11502	7.49x10 <sup>-5</sup> , 0.00089
3	0.569+j1.369	0.04781+j0.11502	7.49x10 <sup>-5</sup> , 0.00089

Per unit data are base on 100 MA & 34.5 kV.

