



**NORTHLAND
POWER**

North Burgess Solar Project Baseline Well Water Monitoring Program and Construction Response Plan

November 11, 2011



Northland Power Inc.
on behalf of
Northland Power Solar
North Burgess L.P.
Toronto, Ontario

Baseline Well Water
Monitoring Program and
Construction Response Plan

North Burgess Solar Project

H334844-0000-07-124-0368

Rev. 1

November 11, 2011

Disclaimer

This report has been prepared by or on behalf of Northland Power Inc. for submission to the Ontario Ministry of the Environment as part of the Renewable Energy Approval process. The content of this report is not intended for the use of, nor is it intended to be relied upon by, any other person. Neither Northland Power Inc. nor any of its directors, officers, employees, agents or consultants has any liability whatsoever for any loss, damage or injury suffered by any third party arising out of, or in connection with, their use of this report.

Project Report

October 24, 2011

**Northland Power Inc.
North Burgess Solar Project**

Baseline Well Water Monitoring Program and Construction Response Plan

Table of Contents

1. Introduction	3
2. Baseline Well Water Monitoring Program.....	3
3. Construction Response Plan	4

List of Figures

Figure 1.1	Scaled Area Location Plan	5
------------	---------------------------------	---

Blank back

1. Introduction

Northland Power Inc. (Northland) is proposing to construct a 10-MW solar projects within the Township of Tay Valley, entitled the North Burgess Solar Project (Figure 1.1). Through discussions with the Ontario Ministry of the Environment (MOE), Northland has identified a need to conduct baseline well water monitoring at wells in proximity of the Project location. The intent of this monitoring program would be to establish baseline conditions of wells in the area for comparison during construction should a neighbouring well owner identify a concern that their well has been impacted by construction of the Project.

The baseline well water monitoring program, as well as a construction response plan, are outlined below.

2. Baseline Well Water Monitoring Program

All water wells within 500 m of the Project location will be initially identified through the MOE Water Well Records database information. The list of water wells will then be updated with information provided by nearby residents and observations from the area of locations of other wells that may not be within the Water Well Records database.

Once identified, owners of the wells will be identified and contacted by mail. The mailing will include information of the proposed Project, the proposed well water monitoring program, and a survey relating to well conditions.

If the well owner wishes to participate in the well water monitoring program, they will be requested to complete the survey, to the best of their knowledge, within 1 month and return it to Northland. The survey will request information relating to

- well construction (i.e., dug/drilled, soil/bedrock, steel casing/concrete; date of construction)
- groundwater quality (i.e., hardness, pH; submission of previous test results is preferred where available)
- groundwater quantity (i.e., has well ever run dry)
- well locations (i.e., number of users, location of septic system).

Once the completed survey is received, Northland will contact the well owner to discuss their survey responses and to arrange a time where a Northland representative can visit their well to obtain a sample.

At the time of the site visit, the Northland representative will

- measure water level in the well, if accessible
- collect two raw water well samples without treatment (after running water for approximately 5 minutes to clear water distribution pipes or storage tank)
- the first sample will be tested on site for field measurement of pH, temperature, conductivity.

The second water sample will be sent to a certified laboratory for general potable water quality tests including alkalinity, ammonia, bacteria, calcium, chloride, colour, conductivity, DOC, hardness, iron, magnesium, manganese, nitrite, nitrate, pH, potassium, sodium, sulphate, TDS, TSS and turbidity. If an exceedance of the Ontario Drinking Water Standards (ODWS) is noted for any of these test parameters, a repeat sample will be obtained and submitted to the laboratory in order to confirm the exceedance.

The well owner will be provided with the results of the laboratory test once received. Northland will maintain a copy of the test results on file as a reference point for the well, and will prepare a summary report of the survey results for the MOE.


3. Construction Response Plan

Prior to construction, all well owners within a 500-m radius of the Project location will be provided with contact information for Northland, and instructions that should the well owner identify a concern that their well is being impacted by construction activities, although Northland does not anticipate any impacts on nearby wells, they should contact Northland.

Upon receipt of this call, Northland will dispatch a representative to resample the well in accordance with the methodologies outlined in Section 2. The sample will be submitted to the laboratory as “high priority”. Northland will also notify the MOE of the call and the results of the test.

If a problem is confirmed as related to the construction activities at the solar project, then Northland will immediately provide a temporary supply of bottled water. Northland will continue providing bottled water and periodically testing the well until such time as no exceedance of ODWS or a return to baseline conditions (in instances where ODWS exceedances were confirmed) are noted within the samples.

In the remote event that a long-term impact to the well is noted and remediation measures, such as flushing the well and water distribution system, fail to remove exceedances of ODWS, Northland will work with the well owner to remedy the situation.



Legend

- Building
- Road
- Topographic Contour (5 m interval)
- Watercourse
- ▭ Parcel
- - - Project Location
- ▭ 500 m from Project Location

Notes:
 1. Produced by Hatch under licence from Ontario Ministry of Natural Resources, Copyright (c) Queens Printer 2011.
 2. Spatial referencing UTM NAD 83.
 3. Satellite imagery from Google Earth Pro.



Figure 1.1
 Northland Power Inc.
 North Burgess Solar Project
 Scaled Area Location Plan



